



155 Corey Avenue
St. Pete Beach, FL 33706-1839
www.stpetebeach.org

Addendum III

Passe-A-Grille Seawall Rehabilitation and 17th Street Seawall

Issued June 23, 2023

Note that this Addendum does not change the bid due date and time as stated in the above referenced RFB. Sealed bids still must be received by 9:00 AM on 7/11/2023, in the Office of the City Clerk, 155 Corey Avenue, St. Pete Beach Florida at which time they will be publicly opened and read. All bidders are invited to attend this bid opening, which will be held immediately following the closing time specified. Bids received after the deadline will not be accepted.

Q: When the demo and chipping of the existing cap starts, can it be place it along the new sea wall with the riprap rubble?

A: No

Q: Is there any staging area the city has in this location that can be used for material, MOT, and dumpster, equipment storage?

A. Staging and storage will need to be done in the parking spots and Right-of-Way of Pass-a-Grille Way..

Q. Will the new concrete sidewalk need to match the existing sidewalk pattern (octagon) out there now, in some location?

A. Yes, the City will provide a sidewalk stamp for use to match existing.

Q. Is there more information and areas on what the city is clarifying Historic pavers? Plans don't show these areas?

A. The two areas of historic pavers are approximately from Sta 17+00 to Sta 19+00 and from Sta 27+50 to Sta 29+00.

Q. Will the engineer of record accept using crush concrete between exist and new wall, instead of flowable fill

A. Yes, crushed concrete is acceptable.

Q. The tie backs that terminate in the pavement areas (parking stalls) will only need to be compacted with base material (what type of base)and just an Asphalt patch? (What type of Asphalt) no milling or over laying? 100 plus tie backs on the drawing.

A. Tipping plate and/or helical tie backs are to be used. These are to be installed without impacting the roadway.

Q. Will the engineer accept sleeves (PVC) through new wall or cap for existing utilities out there to Merry Pier or any other areas?

A. Yes.

Acknowledge receipt of this addendum by initialing and including this page with the submittal.

Initial _____